

# Water Utility Services, Inc.

21615 Rhodes Rd  
Spring, Texas 77388  
281-290-0704

Client: Inframark  
2002 West Grand Pkwy North, Ste 100  
Katy, TX 77449  
Zachary Willeford

## Test Report

PROJECT LOCATION: New Fairview MUD  
COLLECTION DATE: 09/09/23  
SAMPLE TYPE: Grab

COLLECTED BY: RD  
SAMPLE MATRIX: Potable Water

PARAMETER	WP1 GST	WP2 GST	157 Oak Grove	144 Ridge Top	METHOD	ANALYST	DATE
Free Chlorine, mg/L	2.80	0.96	0.95	1.14	Hach 8021	RD	09/09/23
Hardness, mgCaCO <sub>3</sub> /L	64	94	92	92	Hach 8226	CC	09/11/23
Slime Forming Bacteria, cfu/ml**	negative	negative	negative	negative	BART	RD	09/09/23
Iron Related Bacteria, cfu/ml **	negative	negative	negative	negative	BART	RD	09/09/23
Sulfate Reducing Bacteria, cfu/ml**	negative	negative	negative	negative	BART	RD	09/09/23

\*\* Approximate concentration

**Steve Grychka**

---

Steve Grychka  
Laboratory Director

## Water Utility Services Inc

Sample Delivery Group: L1655382  
Samples Received: 09/13/2023  
Project Number:  
Description: New Fairview MUD 1  
  
Report To: Mr. Steve Grychka  
PO Box 2628  
Spring, TX 77383

Entire Report Reviewed By:



Rodney Shinbaum  
Project Manager

Results relate only to the items tested or calibrated and are reported as rounded values. This test report shall not be reproduced, except in full, without written approval of the laboratory. Where applicable, sampling conducted by Pace Analytical National is performed per guidance provided in laboratory standard operating procedures ENV-SOP-MTJL-0067 and ENV-SOP-MTJL-0068. Where sampling conducted by the customer, results relate to the accuracy of the information provided, and as the samples are received.

Pace Analytical National

12065 Lebanon Rd Mount Juliet, TN 37122 615-758-5858 800-767-5859 [www.pacenational.com](http://www.pacenational.com)

# TABLE OF CONTENTS

<b>Cp: Cover Page</b>	<b>1</b>	<b><sup>1</sup>Cp</b>
<b>Tc: Table of Contents</b>	<b>2</b>	
<b>Ss: Sample Summary</b>	<b>3</b>	<b><sup>2</sup>Tc</b>
<b>Cn: Case Narrative</b>	<b>4</b>	
<b>Sr: Sample Results</b>	<b>5</b>	<b><sup>3</sup>Ss</b>
<b>WP1 GST L1655382-01</b>	<b>5</b>	
<b>WP2 GST L1655382-02</b>	<b>6</b>	<b><sup>4</sup>Cn</b>
<b>157 OAK GROVE L1655382-03</b>	<b>7</b>	<b><sup>5</sup>Sr</b>
<b>144 RIDGETOP L1655382-04</b>	<b>8</b>	
<b>Qc: Quality Control Summary</b>	<b>9</b>	<b><sup>6</sup>Qc</b>
<b>Metals (ICP) by Method 200.7</b>	<b>9</b>	
<b>Metals (ICPMS) by Method 200.8</b>	<b>10</b>	<b><sup>7</sup>Gl</b>
<b>Volatile Organic Compounds (GC/MS) by Method 524.2</b>	<b>12</b>	<b><sup>8</sup>Al</b>
<b>Gl: Glossary of Terms</b>	<b>13</b>	
<b>Al: Accreditations &amp; Locations</b>	<b>14</b>	<b><sup>9</sup>Sc</b>
<b>Sc: Sample Chain of Custody</b>	<b>15</b>	

# SAMPLE SUMMARY

## WP1 GST L1655382-01 DW

Collected by: Ryan Deculus  
 Collected date/time: 09/09/23 13:18  
 Received date/time: 09/13/23 09:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2134650	1	09/20/23 11:29	09/21/23 01:07	ZSA	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/22/23 20:34	JPD	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/23/23 15:58	SJM	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2133005	1	09/18/23 06:36	09/18/23 06:36	DWR	Mt. Juliet, TN

1 Cp

2 Tc

3 Ss

4 Cn

5 Sr

6 Qc

7 Gl

8 Al

9 Sc

## WP2 GST L1655382-02 DW

Collected by: Ryan Deculus  
 Collected date/time: 09/09/23 13:35  
 Received date/time: 09/13/23 09:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2134650	1	09/20/23 11:29	09/21/23 01:11	ZSA	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/22/23 20:44	JPD	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/23/23 16:02	SJM	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2133005	1	09/18/23 06:59	09/18/23 06:59	DWR	Mt. Juliet, TN

## 157 OAK GROVE L1655382-03 DW

Collected by: Ryan Deculus  
 Collected date/time: 09/09/23 12:50  
 Received date/time: 09/13/23 09:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2134650	1	09/20/23 11:29	09/21/23 01:14	ZSA	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/22/23 20:47	JPD	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/23/23 16:05	SJM	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2133005	1	09/18/23 07:22	09/18/23 07:22	DWR	Mt. Juliet, TN

## 144 RIDGETOP L1655382-04 DW

Collected by: Ryan Deculus  
 Collected date/time: 09/09/23 13:01  
 Received date/time: 09/13/23 09:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2134650	1	09/20/23 11:29	09/21/23 01:17	ZSA	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/22/23 20:50	JPD	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2134624	1	09/21/23 08:58	09/23/23 16:08	SJM	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2133005	1	09/18/23 07:45	09/18/23 07:45	DWR	Mt. Juliet, TN

# CASE NARRATIVE

All sample aliquots were received at the correct temperature, in the proper containers, with the appropriate preservatives, and within method specified holding times, unless qualified or notated within the report. Where applicable, all MDL (LOD) and RDL (LOQ) values reported for environmental samples have been corrected for the dilution factor used in the analysis. All Method and Batch Quality Control are within established criteria except where addressed in this case narrative, a non-conformance form or properly qualified within the sample results. By my digital signature below, I affirm to the best of my knowledge, all problems/anomalies observed by the laboratory as having the potential to affect the quality of the data have been identified by the laboratory, and no information or data have been knowingly withheld that would affect the quality of the data.



Rodney Shinbaum  
Project Manager

<sup>1</sup> Cp

<sup>2</sup> Tc

<sup>3</sup> Ss

<sup>4</sup> Cn

<sup>5</sup> Sr

<sup>6</sup> Qc

<sup>7</sup> Gl

<sup>8</sup> Al

<sup>9</sup> Sc

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.0731		0.0500	0.30	1	09/21/2023 01:07	<a href="#">WG2134650</a>	ZSA
Strontium	2.12		0.0100		1	09/21/2023 01:07	<a href="#">WG2134650</a>	ZSA

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Antimony	ND		0.00500	0.0060	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Arsenic	ND		0.00100	0.01	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Barium	0.256		0.00500	2	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Beryllium	ND		0.00100	0.0040	1	09/23/2023 15:58	<a href="#">WG2134624</a>	SJM
Cadmium	ND		0.00100	0.0050	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Chromium	ND		0.0200	0.10	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Copper	0.00374		0.00100	1.30	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Lead	ND		0.00200	0.0150	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Manganese	0.00720		0.00500		1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Nickel	ND		0.00200	0.01	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Selenium	ND		0.00200	0.05	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Thallium	ND		0.00100	0.0020	1	09/22/2023 20:34	<a href="#">WG2134624</a>	JPD
Zinc	0.0478		0.0200	5	1	09/23/2023 15:58	<a href="#">WG2134624</a>	SJM

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/18/2023 06:36	<a href="#">WG2133005</a>	DWR
Bromodichloromethane	ND		0.00100		1	09/18/2023 06:36	<a href="#">WG2133005</a>	DWR
Chlorodibromomethane	ND		0.00100		1	09/18/2023 06:36	<a href="#">WG2133005</a>	DWR
Bromoform	0.00182		0.00100		1	09/18/2023 06:36	<a href="#">WG2133005</a>	DWR
Total Trihalomethanes	0.00182		0.00100	0.08	1	09/18/2023 06:36	<a href="#">WG2133005</a>	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.368		0.0500	0.30	1	09/21/2023 01:11	<a href="#">WG2134650</a>	ZSA
Strontium	2.92		0.0100		1	09/21/2023 01:11	<a href="#">WG2134650</a>	ZSA

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Antimony	ND		0.00500	0.0060	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Arsenic	ND		0.00100	0.01	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Barium	0.361		0.00500	2	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Beryllium	ND		0.00100	0.0040	1	09/23/2023 16:02	<a href="#">WG2134624</a>	SJM
Cadmium	ND		0.00100	0.0050	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Chromium	ND		0.0200	0.10	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Copper	0.00738		0.00100	1.30	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Lead	ND		0.00200	0.0150	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Manganese	0.0268		0.00500		1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Nickel	ND		0.00200	0.01	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Selenium	ND		0.00200	0.05	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Thallium	ND		0.00100	0.0020	1	09/22/2023 20:44	<a href="#">WG2134624</a>	JPD
Zinc	0.163		0.0200	5	1	09/23/2023 16:02	<a href="#">WG2134624</a>	SJM

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/18/2023 06:59	<a href="#">WG2133005</a>	DWR
Bromodichloromethane	ND		0.00100		1	09/18/2023 06:59	<a href="#">WG2133005</a>	DWR
Chlorodibromomethane	ND		0.00100		1	09/18/2023 06:59	<a href="#">WG2133005</a>	DWR
Bromoform	0.00683		0.00100		1	09/18/2023 06:59	<a href="#">WG2133005</a>	DWR
Total Trihalomethanes	0.00683		0.00100	0.08	1	09/18/2023 06:59	<a href="#">WG2133005</a>	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.0832		0.0500	0.30	1	09/21/2023 01:14	<a href="#">WG2134650</a>	ZSA
Strontium	3.13		0.0100		1	09/21/2023 01:14	<a href="#">WG2134650</a>	ZSA

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Antimony	ND		0.00500	0.0060	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Arsenic	ND		0.00100	0.01	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Barium	0.417		0.00500	2	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Beryllium	ND		0.00100	0.0040	1	09/23/2023 16:05	<a href="#">WG2134624</a>	SJM
Cadmium	ND		0.00100	0.0050	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Chromium	ND		0.0200	0.10	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Copper	0.0214		0.00100	1.30	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Lead	ND		0.00200	0.0150	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Manganese	0.00683		0.00500		1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Nickel	ND		0.00200	0.01	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Selenium	ND		0.00200	0.05	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Thallium	ND		0.00100	0.0020	1	09/22/2023 20:47	<a href="#">WG2134624</a>	JPD
Zinc	0.0291		0.0200	5	1	09/23/2023 16:05	<a href="#">WG2134624</a>	SJM

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/18/2023 07:22	<a href="#">WG2133005</a>	DWR
Bromodichloromethane	ND		0.00100		1	09/18/2023 07:22	<a href="#">WG2133005</a>	DWR
Chlorodibromomethane	0.00115		0.00100		1	09/18/2023 07:22	<a href="#">WG2133005</a>	DWR
Bromoform	0.00709		0.00100		1	09/18/2023 07:22	<a href="#">WG2133005</a>	DWR
Total Trihalomethanes	0.00824		0.00100	0.08	1	09/18/2023 07:22	<a href="#">WG2133005</a>	DWR



Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.0621		0.0500	0.30	1	09/21/2023 01:17	<a href="#">WG2134650</a>	ZSA
Strontium	3.32		0.0100		1	09/21/2023 01:17	<a href="#">WG2134650</a>	ZSA

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Antimony	ND		0.00500	0.0060	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Arsenic	ND		0.00100	0.01	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Barium	0.444		0.00500	2	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Beryllium	ND		0.00100	0.0040	1	09/23/2023 16:08	<a href="#">WG2134624</a>	SJM
Cadmium	ND		0.00100	0.0050	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Chromium	ND		0.0200	0.10	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Copper	0.0109		0.00100	1.30	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Lead	ND		0.00200	0.0150	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Manganese	0.00788		0.00500		1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Nickel	ND		0.00200	0.01	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Selenium	ND		0.00200	0.05	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Thallium	ND		0.00100	0.0020	1	09/22/2023 20:50	<a href="#">WG2134624</a>	JPD
Zinc	0.0254		0.0200	5	1	09/23/2023 16:08	<a href="#">WG2134624</a>	SJM

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/18/2023 07:45	<a href="#">WG2133005</a>	DWR
Bromodichloromethane	ND		0.00100		1	09/18/2023 07:45	<a href="#">WG2133005</a>	DWR
Chlorodibromomethane	0.00109		0.00100		1	09/18/2023 07:45	<a href="#">WG2133005</a>	DWR
Bromoform	0.00877		0.00100		1	09/18/2023 07:45	<a href="#">WG2133005</a>	DWR
Total Trihalomethanes	0.00986		0.00100	0.08	1	09/18/2023 07:45	<a href="#">WG2133005</a>	DWR

Method Blank (MB)

(MB) R3975716-1 09/21/23 00:53

Analyte	MB Result	MB Qualifier	MB MDL	MB RDL
	mg/l		mg/l	mg/l
Iron	U		0.0205	0.0500
Strontium	U		0.000683	0.0100

Laboratory Control Sample (LCS)

(LCS) R3975716-2 09/21/23 00:56

Analyte	Spike Amount	LCS Result	LCS Rec.	Rec. Limits	LCS Qualifier
	mg/l	mg/l	%	%	
Iron	10.0	9.71	97.1	85.0-115	
Strontium	1.00	0.975	97.5	85.0-115	

L1656141-02 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1656141-02 09/21/23 00:59 • (MS) R3975716-3 09/21/23 01:02 • (MSD) R3975716-4 09/21/23 01:04

Analyte	Spike Amount	Original Result	MS Result	MSD Result	MS Rec.	MSD Rec.	Dilution	Rec. Limits	MS Qualifier	MSD Qualifier	RPD	RPD Limits
	mg/l	mg/l	mg/l	mg/l	%	%		%			%	%
Iron	10.0	0.304	9.66	9.76	93.6	94.6	1	75.0-125			1.02	20
Strontium	1.00	0.386	1.34	1.35	95.5	95.9	1	75.0-125			0.329	20

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Method Blank (MB)

(MB) R3976784-1 09/22/23 20:17

Analyte	MB Result mg/l	MB Qualifier	MB MDL mg/l	MB RDL mg/l
Aluminum	U		0.0470	0.100
Antimony	U		0.00172	0.00500
Arsenic	U		0.000195	0.00100
Barium	U		0.000476	0.00500
Cadmium	U		0.000160	0.00100
Chromium	U		0.00560	0.0200
Copper	U		0.000670	0.00100
Lead	U		0.000513	0.00200
Manganese	U		0.000982	0.00500
Nickel	U		0.000514	0.00200
Selenium	U		0.000437	0.00200
Thallium	U		0.000176	0.00100

<sup>1</sup>Cp

<sup>2</sup>Tc

<sup>3</sup>Ss

<sup>4</sup>Cn

<sup>5</sup>Sr

<sup>6</sup>Qc

<sup>7</sup>Gl

<sup>8</sup>Al

<sup>9</sup>Sc

Method Blank (MB)

(MB) R3977008-1 09/23/23 15:42

Analyte	MB Result mg/l	MB Qualifier	MB MDL mg/l	MB RDL mg/l
Beryllium	U		0.000201	0.00100
Zinc	U		0.00796	0.0200

Laboratory Control Sample (LCS)

(LCS) R3976784-2 09/22/23 20:21

Analyte	Spike Amount mg/l	LCS Result mg/l	LCS Rec. %	Rec. Limits %	LCS Qualifier
Aluminum	1.00	1.08	108	85.0-115	
Antimony	0.0500	0.0499	99.8	85.0-115	
Arsenic	0.0500	0.0526	105	85.0-115	
Barium	0.0500	0.0524	105	85.0-115	
Cadmium	0.0500	0.0528	106	85.0-115	
Chromium	0.0500	0.0550	110	85.0-115	
Copper	0.0500	0.0526	105	85.0-115	
Lead	0.0500	0.0541	108	85.0-115	
Manganese	0.0500	0.0554	111	85.0-115	
Nickel	0.0500	0.0537	107	85.0-115	
Selenium	0.0500	0.0546	109	85.0-115	
Thallium	0.0500	0.0546	109	85.0-115	

Laboratory Control Sample (LCS)

(LCS) R3977008-2 09/23/23 15:45

Analyte	Spike Amount mg/l	LCS Result mg/l	LCS Rec. %	Rec. Limits %	<u>LCS Qualifier</u>
Beryllium	0.0500	0.0523	105	85.0-115	
Zinc	0.0500	0.0524	105	85.0-115	

L1655383-01 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1655383-01 09/22/23 20:24 • (MS) R3976784-3 09/22/23 20:27 • (MSD) R3976784-4 09/22/23 20:30

Analyte	Spike Amount mg/l	Original Result mg/l	MS Result mg/l	MSD Result mg/l	MS Rec. %	MSD Rec. %	Dilution	Rec. Limits %	<u>MS Qualifier</u>	<u>MSD Qualifier</u>	RPD %	RPD Limits %
Aluminum	1.00	ND	1.09	1.08	109	108	1	70.0-130			0.358	20
Antimony	0.0500	ND	0.0520	0.0519	104	104	1	70.0-130			0.0395	20
Arsenic	0.0500	0.00533	0.0588	0.0580	107	105	1	70.0-130			1.34	20
Barium	0.0500	0.156	0.213	0.212	115	112	1	70.0-130			0.749	20
Cadmium	0.0500	ND	0.0516	0.0517	103	103	1	70.0-130			0.0683	20
Chromium	0.0500	ND	0.0530	0.0524	106	105	1	70.0-130			1.13	20
Copper	0.0500	0.00634	0.0580	0.0579	103	103	1	70.0-130			0.215	20
Lead	0.0500	ND	0.0606	0.0590	121	118	1	70.0-130			2.62	20
Manganese	0.0500	0.0132	0.0663	0.0658	106	105	1	70.0-130			0.681	20
Nickel	0.0500	ND	0.0526	0.0530	105	106	1	70.0-130			0.771	20
Selenium	0.0500	ND	0.0536	0.0542	107	108	1	70.0-130			1.19	20
Thallium	0.0500	ND	0.0523	0.0529	105	106	1	70.0-130			1.19	20

L1655383-01 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1655383-01 09/23/23 15:48 • (MS) R3977008-3 09/23/23 15:52 • (MSD) R3977008-4 09/23/23 15:55

Analyte	Spike Amount mg/l	Original Result mg/l	MS Result mg/l	MSD Result mg/l	MS Rec. %	MSD Rec. %	Dilution	Rec. Limits %	<u>MS Qualifier</u>	<u>MSD Qualifier</u>	RPD %	RPD Limits %
Beryllium	0.0500	ND	0.0535	0.0525	107	105	1	70.0-130			1.82	20
Zinc	0.0500	0.0398	0.0600	0.0593	40.4	38.9	1	70.0-130	<u>J6</u>	<u>J6</u>	1.32	20

1 Cp

2 Tc

3 Ss

4 Cn

5 Sr

6 Qc

7 Gl

8 Al

9 Sc

Method Blank (MB)

(MB) R3976519-2 09/18/23 02:44

Analyte	MB Result mg/l	MB Qualifier	MB MDL mg/l	MB RDL mg/l
Chloroform	U		0.0000800	0.00100
Bromodichloromethane	U		0.0000810	0.00100
Chlorodibromomethane	U		0.0000930	0.00100
Bromoform	U		0.0000800	0.00100
Total Trihalomethanes	U		0.000334	0.00100

Laboratory Control Sample (LCS)

(LCS) R3976519-1 09/18/23 01:58

Analyte	Spike Amount mg/l	LCS Result mg/l	LCS Rec. %	Rec. Limits %	LCS Qualifier
Chloroform	0.00500	0.00512	102	70.0-130	
Bromodichloromethane	0.00500	0.00503	101	70.0-130	
Chlorodibromomethane	0.00500	0.00489	97.8	70.0-130	
Bromoform	0.00500	0.00474	94.8	70.0-130	
Total Trihalomethanes	0.0200	0.0198	99.0	70.0-130	

<sup>1</sup> Cp

<sup>2</sup> Tc

<sup>3</sup> Ss

<sup>4</sup> Cn

<sup>5</sup> Sr

<sup>6</sup> Qc

<sup>7</sup> Gl

<sup>8</sup> Al

<sup>9</sup> Sc

# GLOSSARY OF TERMS

## Guide to Reading and Understanding Your Laboratory Report

The information below is designed to better explain the various terms used in your report of analytical results from the Laboratory. This is not intended as a comprehensive explanation, and if you have additional questions please contact your project representative.


Results Disclaimer - Information that may be provided by the customer, and contained within this report, include Permit Limits, Project Name, Sample ID, Sample Matrix, Sample Preservation, Field Blanks, Field Spikes, Field Duplicates, On-Site Data, Sampling Collection Dates/Times, and Sampling Location. Results relate to the accuracy of this information provided, and as the samples are received.

### Abbreviations and Definitions

MDL	Method Detection Limit.
ND	Not detected at the Reporting Limit (or MDL where applicable).
RDL	Reported Detection Limit.
Rec.	Recovery.
RPD	Relative Percent Difference.
SDG	Sample Delivery Group.
U	Not detected at the Reporting Limit (or MDL where applicable).
Analyte	The name of the particular compound or analysis performed. Some Analyses and Methods will have multiple analytes reported.
Dilution	If the sample matrix contains an interfering material, the sample preparation volume or weight values differ from the standard, or if concentrations of analytes in the sample are higher than the highest limit of concentration that the laboratory can accurately report, the sample may be diluted for analysis. If a value different than 1 is used in this field, the result reported has already been corrected for this factor.
Limits	These are the target % recovery ranges or % difference value that the laboratory has historically determined as normal for the method and analyte being reported. Successful QC Sample analysis will target all analytes recovered or duplicated within these ranges.
Original Sample	The non-spiked sample in the prep batch used to determine the Relative Percent Difference (RPD) from a quality control sample. The Original Sample may not be included within the reported SDG.
Qualifier	This column provides a letter and/or number designation that corresponds to additional information concerning the result reported. If a Qualifier is present, a definition per Qualifier is provided within the Glossary and Definitions page and potentially a discussion of possible implications of the Qualifier in the Case Narrative if applicable.
Result	The actual analytical final result (corrected for any sample specific characteristics) reported for your sample. If there was no measurable result returned for a specific analyte, the result in this column may state "ND" (Not Detected) or "BDL" (Below Detectable Levels). The information in the results column should always be accompanied by either an MDL (Method Detection Limit) or RDL (Reporting Detection Limit) that defines the lowest value that the laboratory could detect or report for this analyte.
Uncertainty (Radiochemistry)	Confidence level of 2 sigma.
Case Narrative (Cn)	A brief discussion about the included sample results, including a discussion of any non-conformances to protocol observed either at sample receipt by the laboratory from the field or during the analytical process. If present, there will be a section in the Case Narrative to discuss the meaning of any data qualifiers used in the report.
Quality Control Summary (Qc)	This section of the report includes the results of the laboratory quality control analyses required by procedure or analytical methods to assist in evaluating the validity of the results reported for your samples. These analyses are not being performed on your samples typically, but on laboratory generated material.
Sample Chain of Custody (Sc)	This is the document created in the field when your samples were initially collected. This is used to verify the time and date of collection, the person collecting the samples, and the analyses that the laboratory is requested to perform. This chain of custody also documents all persons (excluding commercial shippers) that have had control or possession of the samples from the time of collection until delivery to the laboratory for analysis.
Sample Results (Sr)	This section of your report will provide the results of all testing performed on your samples. These results are provided by sample ID and are separated by the analyses performed on each sample. The header line of each analysis section for each sample will provide the name and method number for the analysis reported.
Sample Summary (Ss)	This section of the Analytical Report defines the specific analyses performed for each sample ID, including the dates and times of preparation and/or analysis.

### Qualifier Description

J6	The sample matrix interfered with the ability to make any accurate determination; spike value is low.
----	---



# ACCREDITATIONS & LOCATIONS


## Pace Analytical National 12065 Lebanon Rd Mount Juliet, TN 37122

Alabama	40660	Nebraska	NE-OS-15-05
Alaska	17-026	Nevada	TN000032021-1
Arizona	AZ0612	New Hampshire	2975
Arkansas	88-0469	New Jersey–NELAP	TN002
California	2932	New Mexico <sup>1</sup>	TN00003
Colorado	TN00003	New York	11742
Connecticut	PH-0197	North Carolina	Env375
Florida	E87487	North Carolina <sup>1</sup>	DW21704
Georgia	NELAP	North Carolina <sup>3</sup>	41
Georgia <sup>1</sup>	923	North Dakota	R-140
Idaho	TN00003	Ohio–VAP	CL0069
Illinois	200008	Oklahoma	9915
Indiana	C-TN-01	Oregon	TN200002
Iowa	364	Pennsylvania	68-02979
Kansas	E-10277	Rhode Island	LA000356
Kentucky <sup>1,6</sup>	KY90010	South Carolina	84004002
Kentucky <sup>2</sup>	16	South Dakota	n/a
Louisiana	AI30792	Tennessee <sup>1,4</sup>	2006
Louisiana	LA018	Texas	T104704245-20-18
Maine	TN00003	Texas <sup>5</sup>	LAB0152
Maryland	324	Utah	TN000032021-11
Massachusetts	M-TN003	Vermont	VT2006
Michigan	9958	Virginia	110033
Minnesota	047-999-395	Washington	C847
Mississippi	TN00003	West Virginia	233
Missouri	340	Wisconsin	998093910
Montana	CERT0086	Wyoming	A2LA
A2LA – ISO 17025	1461.01	AIHA-LAP,LLC EMLAP	100789
A2LA – ISO 17025 <sup>5</sup>	1461.02	DOD	1461.01
Canada	1461.01	USDA	P330-15-00234
EPA–Crypto	TN00003		

<sup>1</sup> Drinking Water <sup>2</sup> Underground Storage Tanks <sup>3</sup> Aquatic Toxicity <sup>4</sup> Chemical/Microbiological <sup>5</sup> Mold <sup>6</sup> Wastewater n/a Accreditation not applicable

\* Not all certifications held by the laboratory are applicable to the results reported in the attached report.

\* Accreditation is only applicable to the test methods specified on each scope of accreditation held by Pace Analytical.



Water Utility Services, Inc


21615 Rhodes Rd.  
Spring, TX 77388

Billing Information:

Water Utility Services  
P.O. Box 2628  
Spring, TX 77383

Pres  
Chk

Analysis / Container / Preservative



12065 Lebanon Rd  
Mount Juliet, TN 37122  
Phone: 615-758-5858  
Phone: 800-767-5859  
Fax: 615-758-5859



Report to:  
Steve Grychka

Email To:  
steve@waterutilityservice.com

Project Description: *New Fairview MUD 1*

City/State  
Collected: *TX*

Phone: 281-290-0704  
Fax:

Client Project #

Lab Project #

Collected by (print):  
*Ryan Deculus*

Site/Facility ID #

P.O. #

Collected by (signature):

**Rush?** (Lab MUST Be Notified)

Quote #

Same Day  Five Day  
 Next Day  5 Day (Rad Only)  
 Two Day  10 Day (Rad Only)  
 Three Day

Date Results Needed

*9-23-23*

No.  
of  
Cntrs

Immediately Packed on Ice N  Y

Sample ID	Comp/Grab	Matrix *	Depth	Date	Time	No. of Cntrs	As	Co	Cr	Cu	Ni	Pb	Zn	Fe	Mn	Sb	Ba	Be	Se	Tl	Sr	Al	
WP1 GST	G	DW		9-9-23	13:18	3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
WP2 GST	G	DW			13:35	3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
157 Oak Grove	G	PW			12:50	3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
144 Ridge top	G	PW			13:01	3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

L# *1655382*

**D011**

Acctnum: WATERSTX01

Template:

Prelogin:

TSR: Rodney Shinbaum

PB:

Shipped Via:

Remarks Sample # (lab only)

Cl <sub>2</sub> - 2.8	-01
Cl <sub>2</sub> - 0.96	-02
Cl <sub>2</sub> - 0.95	-03
Cl <sub>2</sub> - 1.14	-04

\* Matrix:  
SS - Soil AIR - Air F - Filter  
GW - Groundwater B - Bioassay  
WW - WasteWater  
DW - Drinking Water  
OT - Other

Remarks:

Samples returned via:  
 UPS  FedEx  Courier

Tracking # *6841 8348 9232*

pH \_\_\_\_\_ Temp \_\_\_\_\_  
Flow \_\_\_\_\_ Other \_\_\_\_\_

Sample Receipt Checklist	
COC Seal Present/Intact:	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N
COC Signed/Accurate:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N
Bottles arrive intact:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N
Correct bottles used:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N
Sufficient volume sent:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N
If Applicable	
VOA Zero Headspace:	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N
Preservation Correct/Checked:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N

Relinquished by: (Signature) *[Signature]*

Date: *9-12-23* Time: *11:58*

Received by: (Signature) *[Signature]*

Trip Blank Received: Yes/No  
HCL/MeOH  
TBR

Relinquished by: (Signature) *[Signature]*

Date: *9-12-23* Time: *1800*

Received by: (Signature)

Temp: *DRAGC* Bottles Received: *1240=107 12*

If preservation required by Login: Date/Time

Relinquished by: (Signature)

Date: Time:

Received for lab by: (Signature) *Alexa Mitchell@*

Date: *9/23/23* Time: *0900*

Hold: Condition: NCF /  OK