


Water Utility Services, Inc.
Bacteriological Test Report
December 2023

| Sample ID | PWSID | PWS Name | Sample Site | County | Collection Date | Collection Time | Collector | Analysis Time | System Type | Sample Type | Source | Chlorine mg/L | Total Coliform | E. coli |
|-----------|---------|--------------------|--------------|--------|-----------------|-----------------|-----------|---------------|-------------|--------------|--------|---------------|----------------|-----------|
| 12232756 | 2490092 | New Fairview MUD 1 | 144 Ridgetop | Wise | 12/16/23 | 13:15 | RD | 19:30 | Public | Distribution | Well | 1.55 | not found | not found |
| 12232757 | 2490092 | New Fairview MUD 1 | G2490092B | Wise | 12/16/23 | 13:35 | RD | 19:30 | Public | Raw Well | Well | 0.00 | not found | not found |

DocuSigned by:

 719D3D3EE9C243C...
 Steve Grychka
 Laboratory Director

Water Utility Services, Inc.
 21615 Rhodes Rd
 Spring, Texas 77388
 281-290-0704
 Page 1 of 1

Chlorine - Lake = total, Well = free

NELAP Accredited T104704311-22-15
Method: modified Colitag