

Water Utility Services, Inc.

21615 Rhodes Rd
Spring, Texas 77388
281-290-0704

Client: Inframark
2002 West Grand Pkwy North, Ste 100
Katy, TX 77449
Zachary Willeford

Test Report

PROJECT LOCATION: New Fairview MUD
COLLECTION DATE: 04/06/24
SAMPLE TYPE: Grab

COLLECTED BY: RD
SAMPLE MATRIX: Potable Water

PARAMETER	WP1 GST	WP2 GST	157 Oak Grove	144 Ridge Top	METHOD	ANALYST	DATE
pH, s.u.	8.50	8.47	8.39	8.41	EPA 150.1	RD	04/06/24
Free Chlorine, mg/L	4.00	4.10	3.20	3.10	Hach 8021	RD	04/06/24
Hardness, mgCaCO ₃ /L	20	22	20	30	Hach 8226	TC	04/08/24
Slime Forming Bacteria, cfu/ml**	negative	negative	negative	negative	BART	RD	04/06/24
Iron Related Bacteria, cfu/ml **	9000	9000	2200	negative	BART	RD	04/06/24
Sulfate Reducing Bacteria, cfu/ml**	negative	negative	negative	negative	BART	RD	04/06/24

** Approximate concentration

Steve Grychka

Steve Grychka
Laboratory Director

Water Utility Services Inc

Sample Delivery Group: L1725680
Samples Received: 04/13/2024
Project Number:
Description: New Fairview MUD 1

Report To: Mr. Steve Grychka
PO Box 2628
Spring, TX 77383

Entire Report Reviewed By:



Rodney Shinbaum
Project Manager


Results relate only to the items tested or calibrated and are reported as rounded values. This test report shall not be reproduced, except in full, without written approval of the laboratory. Where applicable, sampling conducted by Pace Analytical National is performed per guidance provided in laboratory standard operating procedures ENV-SOP-MTJL-0067 and ENV-SOP-MTJL-0068. Where sampling conducted by the customer, results relate to the accuracy of the information provided, and as the samples are received.

Pace Analytical National

12065 Lebanon Rd Mount Juliet, TN 37122 615-758-5858 800-767-5859 www.pacenational.com

TABLE OF CONTENTS

Cp: Cover Page	1
Tc: Table of Contents	2
Ss: Sample Summary	3
Cn: Case Narrative	4
Sr: Sample Results	5
WP1 GST L1725680-01	5
WP2 GST L1725680-02	6
157 OAK GROVE L1725680-03	7
144 RIDGE TOP L1725680-04	8
Qc: Quality Control Summary	9
Metals (ICP) by Method 200.7	9
Metals (ICPMS) by Method 200.8	11
Volatile Organic Compounds (GC/MS) by Method 524.2	15
Gl: Glossary of Terms	16
Al: Accreditations & Locations	17
Sc: Sample Chain of Custody	18



SAMPLE SUMMARY

WP1 GST L1725680-01 DW

Collected by: Ryan Deculus
 Collected date/time: 04/06/24 13:00
 Received date/time: 04/13/24 08:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2267387	1	04/18/24 12:15	04/19/24 18:04	ZSA	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2273674	1	04/25/24 06:46	04/25/24 22:00	LD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2267166	1	04/15/24 12:13	04/15/24 12:13	DWR	Mt. Juliet, TN



WP2 GST L1725680-02 DW

Collected by: Ryan Deculus
 Collected date/time: 04/06/24 13:06
 Received date/time: 04/13/24 08:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2269854	1	04/21/24 08:39	04/22/24 00:11	DJS	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2273674	1	04/25/24 06:46	04/25/24 22:03	LD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2267166	1	04/15/24 12:36	04/15/24 12:36	DWR	Mt. Juliet, TN

157 OAK GROVE L1725680-03 DW

Collected by: Ryan Deculus
 Collected date/time: 04/06/24 13:25
 Received date/time: 04/13/24 08:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2267387	1	04/18/24 12:15	04/19/24 18:06	ZSA	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2267382	1	04/24/24 10:38	04/24/24 20:12	LD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2267166	1	04/15/24 13:00	04/15/24 13:00	DWR	Mt. Juliet, TN

144 RIDGE TOP L1725680-04 DW

Collected by: Ryan Deculus
 Collected date/time: 04/06/24 13:16
 Received date/time: 04/13/24 08:00

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2267387	1	04/18/24 12:15	04/19/24 18:08	ZSA	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2267382	1	04/24/24 10:38	04/24/24 20:51	LD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2267166	1	04/15/24 13:23	04/15/24 13:23	DWR	Mt. Juliet, TN

CASE NARRATIVE

All sample aliquots were received at the correct temperature, in the proper containers, with the appropriate preservatives, and within method specified holding times, unless qualified or notated within the report. Where applicable, all MDL (LOD) and RDL (LOQ) values reported for environmental samples have been corrected for the dilution factor used in the analysis. All Method and Batch Quality Control are within established criteria except where addressed in this case narrative, a non-conformance form or properly qualified within the sample results. By my digital signature below, I affirm to the best of my knowledge, all problems/anomalies observed by the laboratory as having the potential to affect the quality of the data have been identified by the laboratory, and no information or data have been knowingly withheld that would affect the quality of the data.



Rodney Shinbaum
Project Manager

¹ Cp

² Tc

³ Ss

⁴ Cn

⁵ Sr

⁶ Qc

⁷ Gl

⁸ Al

⁹ Sc

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.256		0.0500	0.30	1	04/19/2024 18:04	WG2267387	ZSA
Strontium	0.666		0.0100		1	04/19/2024 18:04	WG2267387	ZSA

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	04/25/2024 22:00	WG2273674	LD
Antimony	ND		0.00500	0.0060	1	04/25/2024 22:00	WG2273674	LD
Arsenic	ND		0.00100	0.01	1	04/25/2024 22:00	WG2273674	LD
Barium	0.0324		0.00500	2	1	04/25/2024 22:00	WG2273674	LD
Beryllium	ND		0.00100	0.0040	1	04/25/2024 22:00	WG2273674	LD
Cadmium	ND		0.00100	0.0050	1	04/25/2024 22:00	WG2273674	LD
Chromium	ND		0.0200	0.10	1	04/25/2024 22:00	WG2273674	LD
Copper	0.00396		0.00100	1.30	1	04/25/2024 22:00	WG2273674	LD
Lead	ND		0.00200	0.0150	1	04/25/2024 22:00	WG2273674	LD
Manganese	0.00920		0.00500		1	04/25/2024 22:00	WG2273674	LD
Nickel	ND		0.00200	0.01	1	04/25/2024 22:00	WG2273674	LD
Selenium	ND		0.00200	0.05	1	04/25/2024 22:00	WG2273674	LD
Thallium	ND		0.00100	0.0020	1	04/25/2024 22:00	WG2273674	LD
Zinc	ND		0.0200	5	1	04/25/2024 22:00	WG2273674	LD

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	04/15/2024 12:13	WG2267166	DWR
Bromodichloromethane	ND		0.00100		1	04/15/2024 12:13	WG2267166	DWR
Chlorodibromomethane	ND		0.00100		1	04/15/2024 12:13	WG2267166	DWR
Bromoform	ND		0.00100		1	04/15/2024 12:13	WG2267166	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	04/15/2024 12:13	WG2267166	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.723		0.0500	0.30	1	04/22/2024 00:11	WG2269854	DJS
Strontium	0.695		0.0100		1	04/22/2024 00:11	WG2269854	DJS

1 Cp

2 Tc

3 Ss

4 Cn

5 Sr

6 Qc

7 Gl

8 Al

9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	04/25/2024 22:03	WG2273674	LD
Antimony	ND		0.00500	0.0060	1	04/25/2024 22:03	WG2273674	LD
Arsenic	ND		0.00100	0.01	1	04/25/2024 22:03	WG2273674	LD
Barium	0.0358		0.00500	2	1	04/25/2024 22:03	WG2273674	LD
Beryllium	ND		0.00100	0.0040	1	04/25/2024 22:03	WG2273674	LD
Cadmium	ND		0.00100	0.0050	1	04/25/2024 22:03	WG2273674	LD
Chromium	ND		0.0200	0.10	1	04/25/2024 22:03	WG2273674	LD
Copper	0.00306		0.00100	1.30	1	04/25/2024 22:03	WG2273674	LD
Lead	ND		0.00200	0.0150	1	04/25/2024 22:03	WG2273674	LD
Manganese	0.00978		0.00500		1	04/25/2024 22:03	WG2273674	LD
Nickel	ND		0.00200	0.01	1	04/25/2024 22:03	WG2273674	LD
Selenium	ND		0.00200	0.05	1	04/25/2024 22:03	WG2273674	LD
Thallium	ND		0.00100	0.0020	1	04/25/2024 22:03	WG2273674	LD
Zinc	0.0410		0.0200	5	1	04/25/2024 22:03	WG2273674	LD

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	04/15/2024 12:36	WG2267166	DWR
Bromodichloromethane	ND		0.00100		1	04/15/2024 12:36	WG2267166	DWR
Chlorodibromomethane	ND		0.00100		1	04/15/2024 12:36	WG2267166	DWR
Bromoform	ND		0.00100		1	04/15/2024 12:36	WG2267166	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	04/15/2024 12:36	WG2267166	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.196		0.0500	0.30	1	04/19/2024 18:06	WG2267387	ZSA
Strontium	0.977		0.0100		1	04/19/2024 18:06	WG2267387	ZSA

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	04/24/2024 20:12	WG2267382	LD
Antimony	ND		0.00500	0.0060	1	04/24/2024 20:12	WG2267382	LD
Arsenic	ND		0.00100	0.01	1	04/24/2024 20:12	WG2267382	LD
Barium	0.0649		0.00500	2	1	04/24/2024 20:12	WG2267382	LD
Beryllium	ND		0.00100	0.0040	1	04/24/2024 20:12	WG2267382	LD
Cadmium	ND		0.00100	0.0050	1	04/24/2024 20:12	WG2267382	LD
Chromium	ND		0.0200	0.10	1	04/24/2024 20:12	WG2267382	LD
Copper	0.0237		0.00100	1.30	1	04/24/2024 20:12	WG2267382	LD
Lead	ND		0.00200	0.0150	1	04/24/2024 20:12	WG2267382	LD
Manganese	0.00554		0.00500		1	04/24/2024 20:12	WG2267382	LD
Nickel	ND		0.00200	0.01	1	04/24/2024 20:12	WG2267382	LD
Selenium	ND		0.00200	0.05	1	04/24/2024 20:12	WG2267382	LD
Thallium	ND		0.00100	0.0020	1	04/24/2024 20:12	WG2267382	LD
Zinc	ND		0.0200	5	1	04/24/2024 20:12	WG2267382	LD

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	04/15/2024 13:00	WG2267166	DWR
Bromodichloromethane	ND		0.00100		1	04/15/2024 13:00	WG2267166	DWR
Chlorodibromomethane	ND		0.00100		1	04/15/2024 13:00	WG2267166	DWR
Bromoform	ND		0.00100		1	04/15/2024 13:00	WG2267166	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	04/15/2024 13:00	WG2267166	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Iron	0.212		0.0500	0.30	1	04/19/2024 18:08	WG2267387	ZSA
Strontium	0.652		0.0100		1	04/19/2024 18:08	WG2267387	ZSA

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	04/24/2024 20:51	WG2267382	LD
Antimony	ND		0.00500	0.0060	1	04/24/2024 20:51	WG2267382	LD
Arsenic	ND		0.00100	0.01	1	04/24/2024 20:51	WG2267382	LD
Barium	0.0412		0.00500	2	1	04/24/2024 20:51	WG2267382	LD
Beryllium	ND		0.00100	0.0040	1	04/24/2024 20:51	WG2267382	LD
Cadmium	ND		0.00100	0.0050	1	04/24/2024 20:51	WG2267382	LD
Chromium	ND		0.0200	0.10	1	04/24/2024 20:51	WG2267382	LD
Copper	0.0285		0.00100	1.30	1	04/24/2024 20:51	WG2267382	LD
Lead	ND		0.00200	0.0150	1	04/24/2024 20:51	WG2267382	LD
Manganese	0.00598		0.00500		1	04/24/2024 20:51	WG2267382	LD
Nickel	ND		0.00200	0.01	1	04/24/2024 20:51	WG2267382	LD
Selenium	ND		0.00200	0.05	1	04/24/2024 20:51	WG2267382	LD
Thallium	ND		0.00100	0.0020	1	04/24/2024 20:51	WG2267382	LD
Zinc	ND		0.0200	5	1	04/24/2024 20:51	WG2267382	LD

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	04/15/2024 13:23	WG2267166	DWR
Bromodichloromethane	ND		0.00100		1	04/15/2024 13:23	WG2267166	DWR
Chlorodibromomethane	ND		0.00100		1	04/15/2024 13:23	WG2267166	DWR
Bromoform	ND		0.00100		1	04/15/2024 13:23	WG2267166	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	04/15/2024 13:23	WG2267166	DWR

Method Blank (MB)

(MB) R4060142-1 04/19/24 17:56

Analyte	MB Result	MB Qualifier	MB MDL	MB RDL
	mg/l		mg/l	mg/l
Iron	U		0.0205	0.0500
Strontium	U		0.000683	0.0100

¹Cp

²Tc

³Ss

⁴Cn

⁵Sr

⁶Qc

⁷Gl

⁸Al

⁹Sc

Laboratory Control Sample (LCS)

(LCS) R4060142-2 04/19/24 17:57

Analyte	Spike Amount	LCS Result	LCS Rec.	Rec. Limits	LCS Qualifier
	mg/l	mg/l	%	%	
Iron	10.0	10.5	105	85.0-115	
Strontium	1.00	1.07	107	85.0-115	

L1725510-01 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1725510-01 04/19/24 17:59 • (MS) R4060142-3 04/19/24 18:01 • (MSD) R4060142-4 04/19/24 18:03

Analyte	Spike Amount	Original Result	MS Result	MSD Result	MS Rec.	MSD Rec.	Dilution	Rec. Limits	MS Qualifier	MSD Qualifier	RPD	RPD Limits
	mg/l	mg/l	mg/l	mg/l	%	%		%			%	%
Iron	10.0	ND	9.98	9.97	99.8	99.7	1	75.0-125			0.0582	20
Strontium	1.00	0.192	1.20	1.21	101	102	1	75.0-125			0.272	20

Method Blank (MB)

(MB) R4060401-1 04/21/24 23:59

Analyte	MB Result mg/l	MB Qualifier	MB MDL mg/l	MB RDL mg/l
Iron	0.0394	↓	0.0205	0.0500
Strontium	U		0.000683	0.0100

Laboratory Control Sample (LCS) • Laboratory Control Sample Duplicate (LCSD)

(LCS) R4060401-2 04/22/24 00:02 • (LCSD) R4060401-3 04/22/24 00:05

Analyte	Spike Amount mg/l	LCS Result mg/l	LCSD Result mg/l	LCS Rec. %	LCSD Rec. %	Rec. Limits %	LCS Qualifier	LCSD Qualifier	RPD %	RPD Limits %
Iron	10.0	10.4	10.4	104	104	85.0-115			0.280	20
Strontium	1.00	1.05	1.04	105	104	85.0-115			0.348	20

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Method Blank (MB)

(MB) R4061717-1 04/24/24 19:41

Analyte	MB Result mg/l	MB Qualifier	MB MDL mg/l	MB RDL mg/l
Aluminum	U		0.0470	0.100
Antimony	U		0.00172	0.00500
Arsenic	U		0.000195	0.00100
Barium	U		0.000476	0.00500
Beryllium	U		0.000201	0.00100
Cadmium	U		0.000160	0.00100
Chromium	U		0.00560	0.0200
Copper	U		0.000670	0.00100
Lead	U		0.000513	0.00200
Manganese	U		0.000982	0.00500
Nickel	U		0.000514	0.00200
Selenium	U		0.000437	0.00200
Thallium	U		0.000176	0.00100
Zinc	U		0.00796	0.0200

¹Cp

²Tc

³Ss

⁴Cn

⁵Sr

⁶Qc

⁷Gl

⁸Al

⁹Sc

Laboratory Control Sample (LCS)

(LCS) R4061717-2 04/24/24 19:45

Analyte	Spike Amount mg/l	LCS Result mg/l	LCS Rec. %	Rec. Limits %	LCS Qualifier
Aluminum	1.00	1.01	101	85.0-115	
Antimony	0.0500	0.0483	96.7	85.0-115	
Arsenic	0.0500	0.0491	98.1	85.0-115	
Barium	0.0500	0.0468	93.6	85.0-115	
Beryllium	0.0500	0.0455	90.9	85.0-115	
Cadmium	0.0500	0.0497	99.4	85.0-115	
Chromium	0.0500	0.0499	99.7	85.0-115	
Copper	0.0500	0.0477	95.4	85.0-115	
Lead	0.0500	0.0466	93.2	85.0-115	
Manganese	0.0500	0.0494	98.8	85.0-115	
Nickel	0.0500	0.0509	102	85.0-115	
Selenium	0.0500	0.0490	97.9	85.0-115	
Thallium	0.0500	0.0476	95.2	85.0-115	
Zinc	0.0500	0.0516	103	85.0-115	

L1725679-02 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1725679-02 04/24/24 19:48 • (MS) R4061717-3 04/24/24 19:52 • (MSD) R4061717-4 04/24/24 19:55

Analyte	Spike Amount mg/l	Original Result mg/l	MS Result mg/l	MSD Result mg/l	MS Rec. %	MSD Rec. %	Dilution	Rec. Limits %	MS Qualifier	MSD Qualifier	RPD %	RPD Limits %
Aluminum	1.00	ND	1.01	1.00	101	100	1	70.0-130			0.572	20
Antimony	0.0500	ND	0.0515	0.0513	103	103	1	70.0-130			0.523	20
Arsenic	0.0500	0.00570	0.0555	0.0564	99.7	101	1	70.0-130			1.53	20
Barium	0.0500	0.203	0.251	0.255	97.1	103	1	70.0-130			1.27	20
Beryllium	0.0500	ND	0.0536	0.0527	107	105	1	70.0-130			1.64	20
Cadmium	0.0500	ND	0.0483	0.0486	96.6	97.2	1	70.0-130			0.573	20
Chromium	0.0500	ND	0.0496	0.0490	99.3	98.1	1	70.0-130			1.22	20
Copper	0.0500	0.00153	0.0520	0.0519	101	101	1	70.0-130			0.209	20
Lead	0.0500	ND	0.0459	0.0468	91.8	93.6	1	70.0-130			1.94	20
Manganese	0.0500	0.0197	0.0691	0.0693	98.8	99.2	1	70.0-130			0.253	20
Nickel	0.0500	ND	0.0502	0.0503	100	101	1	70.0-130			0.103	20
Selenium	0.0500	ND	0.0489	0.0476	97.7	95.2	1	70.0-130			2.61	20
Thallium	0.0500	ND	0.0460	0.0474	92.1	94.8	1	70.0-130			2.93	20
Zinc	0.0500	ND	0.0546	0.0540	109	108	1	70.0-130			1.04	20

- 1 Cp
- 2 Tc
- 3 Ss
- 4 Cn
- 5 Sr
- 6 Qc
- 7 Gl
- 8 Al
- 9 Sc

Method Blank (MB)

(MB) R4062311-1 04/25/24 21:39

Analyte	MB Result mg/l	MB Qualifier	MB MDL mg/l	MB RDL mg/l
Aluminum	U		0.0470	0.100
Antimony	U		0.00172	0.00500
Arsenic	U		0.000195	0.00100
Barium	U		0.000476	0.00500
Beryllium	U		0.000201	0.00100
Cadmium	U		0.000160	0.00100
Chromium	U		0.00560	0.0200
Copper	U		0.000670	0.00100
Lead	U		0.000513	0.00200
Manganese	U		0.000982	0.00500
Nickel	U		0.000514	0.00200
Selenium	U		0.000437	0.00200
Thallium	U		0.000176	0.00100
Zinc	U		0.00796	0.0200

¹Cp

²Tc

³Ss

⁴Cn

⁵Sr

⁶Qc

⁷Gl

⁸Al

⁹Sc

Laboratory Control Sample (LCS)

(LCS) R4062311-3 04/25/24 21:46

Analyte	Spike Amount mg/l	LCS Result mg/l	LCS Rec. %	Rec. Limits %	LCS Qualifier
Aluminum	1.00	0.993	99.3	85.0-115	
Antimony	0.0500	0.0468	93.6	85.0-115	
Arsenic	0.0500	0.0499	99.7	85.0-115	
Barium	0.0500	0.0469	93.7	85.0-115	
Beryllium	0.0500	0.0498	99.6	85.0-115	
Cadmium	0.0500	0.0503	101	85.0-115	
Chromium	0.0500	0.0508	102	85.0-115	
Copper	0.0500	0.0484	96.8	85.0-115	
Lead	0.0500	0.0483	96.6	85.0-115	
Manganese	0.0500	0.0504	101	85.0-115	
Nickel	0.0500	0.0521	104	85.0-115	
Selenium	0.0500	0.0480	96.1	85.0-115	
Thallium	0.0500	0.0471	94.1	85.0-115	
Zinc	0.0500	0.0487	97.3	85.0-115	

L1727009-04 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1727009-04 04/25/24 21:50 • (MS) R4062311-4 04/25/24 21:53 • (MSD) R4062311-5 04/25/24 21:56

Analyte	Spike Amount mg/l	Original Result mg/l	MS Result mg/l	MSD Result mg/l	MS Rec. %	MSD Rec. %	Dilution	Rec. Limits %	MS Qualifier	MSD Qualifier	RPD %	RPD Limits %
Aluminum	1.00	0.245	1.25	1.21	100	96.7	1	70.0-130			2.74	20
Antimony	0.0500	ND	0.0510	0.0493	102	98.5	1	70.0-130			3.45	20
Arsenic	0.0500	ND	0.0528	0.0503	105	99.6	1	70.0-130			4.85	20
Barium	0.0500	0.0533	0.102	0.0982	97.1	89.9	1	70.0-130			3.62	20
Beryllium	0.0500	ND	0.0535	0.0520	107	104	1	70.0-130			2.83	20
Cadmium	0.0500	ND	0.0516	0.0504	103	101	1	70.0-130			2.38	20
Chromium	0.0500	ND	0.0530	0.0503	106	101	1	70.0-130			5.18	20
Copper	0.0500	0.00727	0.0566	0.0557	98.6	96.8	1	70.0-130			1.57	20
Lead	0.0500	ND	0.0520	0.0500	104	100	1	70.0-130			3.91	20
Manganese	0.0500	ND	0.0546	0.0525	101	97.1	1	70.0-130			3.99	20
Nickel	0.0500	ND	0.0549	0.0517	107	100	1	70.0-130			6.01	20
Selenium	0.0500	ND	0.0516	0.0488	103	97.5	1	70.0-130			5.71	20
Thallium	0.0500	ND	0.0491	0.0487	98.3	97.4	1	70.0-130			0.956	20
Zinc	0.0500	0.0529	0.0994	0.0956	93.1	85.4	1	70.0-130			3.93	20

¹ Cp

² Tc

³ Ss

⁴ Cn

⁵ Sr

⁶ Qc

⁷ Gl

⁸ Al

⁹ Sc

Method Blank (MB)

(MB) R4059813-2 04/15/24 11:50

Analyte	MB Result	MB Qualifier	MB MDL	MB RDL
	mg/l		mg/l	mg/l
Chloroform	U		0.0000800	0.00100
Bromodichloromethane	U		0.0000810	0.00100
Chlorodibromomethane	U		0.0000930	0.00100
Bromoform	U		0.0000800	0.00100
Total Trihalomethanes	U		0.000334	0.00100

Laboratory Control Sample (LCS)

(LCS) R4059813-1 04/15/24 11:04

Analyte	Spike Amount	LCS Result	LCS Rec.	Rec. Limits	LCS Qualifier
	mg/l	mg/l	%	%	
Chloroform	0.00500	0.00531	106	70.0-130	
Bromodichloromethane	0.00500	0.00565	113	70.0-130	
Chlorodibromomethane	0.00500	0.00537	107	70.0-130	
Bromoform	0.00500	0.00541	108	70.0-130	
Total Trihalomethanes	0.0200	0.0217	109	70.0-130	

¹ Cp

² Tc

³ Ss

⁴ Cn

⁵ Sr

⁶ Qc

⁷ Gl

⁸ Al

⁹ Sc

GLOSSARY OF TERMS

Guide to Reading and Understanding Your Laboratory Report

The information below is designed to better explain the various terms used in your report of analytical results from the Laboratory. This is not intended as a comprehensive explanation, and if you have additional questions please contact your project representative.


Results Disclaimer - Information that may be provided by the customer, and contained within this report, include Permit Limits, Project Name, Sample ID, Sample Matrix, Sample Preservation, Field Blanks, Field Spikes, Field Duplicates, On-Site Data, Sampling Collection Dates/Times, and Sampling Location. Results relate to the accuracy of this information provided, and as the samples are received.

Abbreviations and Definitions

MDL	Method Detection Limit.
ND	Not detected at the Reporting Limit (or MDL where applicable).
RDL	Reported Detection Limit.
Rec.	Recovery.
RPD	Relative Percent Difference.
SDG	Sample Delivery Group.
U	Not detected at the Reporting Limit (or MDL where applicable).
Analyte	The name of the particular compound or analysis performed. Some Analyses and Methods will have multiple analytes reported.
Dilution	If the sample matrix contains an interfering material, the sample preparation volume or weight values differ from the standard, or if concentrations of analytes in the sample are higher than the highest limit of concentration that the laboratory can accurately report, the sample may be diluted for analysis. If a value different than 1 is used in this field, the result reported has already been corrected for this factor.
Limits	These are the target % recovery ranges or % difference value that the laboratory has historically determined as normal for the method and analyte being reported. Successful QC Sample analysis will target all analytes recovered or duplicated within these ranges.
Original Sample	The non-spiked sample in the prep batch used to determine the Relative Percent Difference (RPD) from a quality control sample. The Original Sample may not be included within the reported SDG.
Qualifier	This column provides a letter and/or number designation that corresponds to additional information concerning the result reported. If a Qualifier is present, a definition per Qualifier is provided within the Glossary and Definitions page and potentially a discussion of possible implications of the Qualifier in the Case Narrative if applicable.
Result	The actual analytical final result (corrected for any sample specific characteristics) reported for your sample. If there was no measurable result returned for a specific analyte, the result in this column may state "ND" (Not Detected) or "BDL" (Below Detectable Levels). The information in the results column should always be accompanied by either an MDL (Method Detection Limit) or RDL (Reporting Detection Limit) that defines the lowest value that the laboratory could detect or report for this analyte.
Uncertainty (Radiochemistry)	Confidence level of 2 sigma.
Case Narrative (Cn)	A brief discussion about the included sample results, including a discussion of any non-conformances to protocol observed either at sample receipt by the laboratory from the field or during the analytical process. If present, there will be a section in the Case Narrative to discuss the meaning of any data qualifiers used in the report.
Quality Control Summary (Qc)	This section of the report includes the results of the laboratory quality control analyses required by procedure or analytical methods to assist in evaluating the validity of the results reported for your samples. These analyses are not being performed on your samples typically, but on laboratory generated material.
Sample Chain of Custody (Sc)	This is the document created in the field when your samples were initially collected. This is used to verify the time and date of collection, the person collecting the samples, and the analyses that the laboratory is requested to perform. This chain of custody also documents all persons (excluding commercial shippers) that have had control or possession of the samples from the time of collection until delivery to the laboratory for analysis.
Sample Results (Sr)	This section of your report will provide the results of all testing performed on your samples. These results are provided by sample ID and are separated by the analyses performed on each sample. The header line of each analysis section for each sample will provide the name and method number for the analysis reported.
Sample Summary (Ss)	This section of the Analytical Report defines the specific analyses performed for each sample ID, including the dates and times of preparation and/or analysis.

Qualifier Description

Qualifier	Description
J	The identification of the analyte is acceptable; the reported value is an estimate.



ACCREDITATIONS & LOCATIONS

Pace Analytical National 12065 Lebanon Rd Mount Juliet, TN 37122

Alabama	40660	Nebraska	NE-OS-15-05
Alaska	17-026	Nevada	TN000032021-1
Arizona	AZ0612	New Hampshire	2975
Arkansas	88-0469	New Jersey–NELAP	TN002
California	2932	New Mexico ¹	TN00003
Colorado	TN00003	New York	11742
Connecticut	PH-0197	North Carolina	Env375
Florida	E87487	North Carolina ¹	DW21704
Georgia	NELAP	North Carolina ³	41
Georgia ¹	923	North Dakota	R-140
Idaho	TN00003	Ohio–VAP	CL0069
Illinois	200008	Oklahoma	9915
Indiana	C-TN-01	Oregon	TN200002
Iowa	364	Pennsylvania	68-02979
Kansas	E-10277	Rhode Island	LA000356
Kentucky ^{1,6}	KY90010	South Carolina	84004002
Kentucky ²	16	South Dakota	n/a
Louisiana	AI30792	Tennessee ^{1,4}	2006
Louisiana	LA018	Texas	T104704245-20-18
Maine	TN00003	Texas ⁵	LAB0152
Maryland	324	Utah	TN000032021-11
Massachusetts	M-TN003	Vermont	VT2006
Michigan	9958	Virginia	110033
Minnesota	047-999-395	Washington	C847
Mississippi	TN00003	West Virginia	233
Missouri	340	Wisconsin	998093910
Montana	CERT0086	Wyoming	A2LA
A2LA – ISO 17025	1461.01	AIHA-LAP,LLC EMLAP	100789
A2LA – ISO 17025 ⁵	1461.02	DOD	1461.01
Canada	1461.01	USDA	P330-15-00234
EPA–Crypto	TN00003		

¹ Drinking Water ² Underground Storage Tanks ³ Aquatic Toxicity ⁴ Chemical/Microbiological ⁵ Mold ⁶ Wastewater n/a Accreditation not applicable

* Not all certifications held by the laboratory are applicable to the results reported in the attached report.

* Accreditation is only applicable to the test methods specified on each scope of accreditation held by Pace Analytical.

¹ Cp

² Tc

³ Ss

⁴ Cn

⁵ Sr

⁶ Qc

⁷ Gl

⁸ Al

⁹ Sc

Water Utility Services, Inc

21615 Rhodes Rd.
Spring, TX 77388

Billing Information:

Water Utility Services
P.O. Box 2628
Spring, TX 77383

Pres
Chk

Analysis / Container / Preservative

Chain of Custody Page ___ of ___



12065 Lebanon Rd
Mount Juliet, TN 37122
Phone: 615-758-5858
Phone: 800-767-5859
Fax: 615-758-5859



Report to:
Steve Grychka

Email To:
steve@waterutilityservice.com

Project Description: *New Fairview MUD 1*

City/State Collected: *TX*

Phone: 281-290-0704
Fax:

Client Project #
Lab Project #

Quote #

Collected by (print):
Ryan Deculus

Site/Facility ID #
P.O. #

Date Results Needed

Collected by (signature):
Immediately Packed on Ice N ___ Y

Rush? (Lab MUST Be Notified)
 Same Day Five Day
 Next Day 5 Day (Rad Only)
 Two Day 10 Day (Rad Only)
 Three Day

No. of Cntrs

Sample ID	Comp/Grab	Matrix *	Depth	Date	Time	No. of Cntrs	Analysis / Container / Preservative														
<i>WPI GST</i>	<i>G</i>	<i>DW</i>		<i>4-6-24</i>	<i>1300</i>	<i>3</i>	<i>TT HMS</i>	<i>L2</i>	<i>L2</i>												
<i>WP2 GST</i>	<i>G</i>	<i>DW</i>		<i>1</i>	<i>1306</i>	<i>3</i>		<i>As, Cd, Cr, Cu, Ni, Pb, Zn, Fe, Mn</i>													
<i>157 Oak Grove</i>	<i>G</i>	<i>DW</i>		<i>1</i>	<i>1325</i>	<i>3</i>															
<i>144 Ridge top</i>	<i>G</i>	<i>DW</i>		<i>1</i>	<i>1316</i>	<i>3</i>															

L# *1725680*

D250

Acctnum: WATERSTX01

Template:

Prelogin:

TSR: Rodney Shinbaum

PB:

Shipped Via:

Remarks Sample # (lab only)

* Matrix:
 SS - Soil AIR - Air F - Filter
 GW - Groundwater B - Bioassay
 WW - WasteWater
 DW - Drinking Water
 OT - Other

Remarks:
 pH _____ Temp _____
 Flow _____ Other _____
 Samples returned via:
 UPS FedEx Courier _____
 Tracking # _____

Sample Receipt Checklist
 COC Seal Present/Intact: NP Y N
 COC Signed/Accurate: Y N
 Bottles arrive intact: Y N
 Correct bottles used: Y N
 Sufficient volume sent: Y N
 If Applicable
 VOA Zero Headspace: Y N
 Preservation Correct/Checked: Y N

Relinquished by: (Signature) *RJ*

Date: *4-12-24*

Time: *11:24*

Received by: (Signature) *CS*

Trip Blank Received: Yes/No
HCL/MeOH
TBR

Relinquished by: (Signature) *CS*

Date: *4-12-24*

Time: *1800*

Received by: (Signature)

Temp: *19.7°C*
9.5 to 1 = 4.6
Bottles Received: *12*

PH-10BDH5021 TRC-2357362
CR6-20221V In: Date/Time

Relinquished by: (Signature)

Date:

Time:

Received for lab by: (Signature) *Charles Stevenson*

Date: *4-13-24* Time: *8:00*

Hold: Condition: *NCF / OK*