

Water Utility Services, Inc.

21615 Rhodes Rd
Spring, Texas 77388
281-290-0704

Client: Inframark
2002 West Grand Pkwy North, Ste 100
Katy, TX 77449

Test Report

PROJECT LOCATION: New Fairview MUD
COLLECTION DATE: 08/23/24
SAMPLE TYPE: Grab

COLLECTED BY: RD
SAMPLE MATRIX: Potable Water

PARAMETER	WP1 GST	WP2 GST	157 Oak Grove	144 Ridge Top	METHOD	ANALYST	DATE
pH, s.u.	8.39	8.44	8.42	8.45	EPA 150.1	RD	08/23/24
Total Chlorine, mg/L	1.81	1.66	1.22	1.62	Hach 8021	RD	08/23/24
Hardness, mgCaCO ₃ /L	86	84	90	86	Hach 8226	TC	08/23/24
Slime Forming Bacteria, cfu/ml**	negative	negative	negative	negative	BART	RD	08/23/24
Iron Related Bacteria, cfu/ml **	9000	9000	500	500	BART	RD	08/23/24
Sulfate Reducing Bacteria, cfu/ml**	negative	negative	negative	negative	BART	RD	08/23/24

** Approximate concentration

Steve Grychka

Steve Grychka
Laboratory Director

Water Utility Services Inc

Sample Delivery Group: L1772209
Samples Received: 08/28/2024
Project Number:
Description: New Fairview MUD 1

Report To: Mr. Steve Grychka
PO Box 2628
Spring, TX 77383

Entire Report Reviewed By:



Rodney Shinbaum
Project Manager

Results relate only to the items tested or calibrated and are reported as rounded values. This test report shall not be reproduced, except in full, without written approval of the laboratory. Where applicable, sampling conducted by Pace Analytical National is performed per guidance provided in laboratory standard operating procedures ENV-SOP-MTJL-0067 and ENV-SOP-MTJL-0068. Where sampling conducted by the customer, results relate to the accuracy of the information provided, and as the samples are received.

Pace Analytical National

12065 Lebanon Rd Mount Juliet, TN 37122 615-758-5858 800-767-5859 mydata.pacelabs.com

TABLE OF CONTENTS

Cp: Cover Page	1
Tc: Table of Contents	2
Ss: Sample Summary	3
Cn: Case Narrative	4
Sr: Sample Results	5
WP1 GST L1772209-01	5
WP2 GST L1772209-02	6
157 OAK GROVE L1772209-03	7
144 RIDGETOP L1772209-04	8
Qc: Quality Control Summary	9
Metals (ICP) by Method 200.7	9
Metals (ICPMS) by Method 200.8	11
Volatile Organic Compounds (GC/MS) by Method 524.2	12
Gl: Glossary of Terms	13
Al: Accreditations & Locations	14
Sc: Sample Chain of Custody	15

¹ Cp

² Tc

³ Ss

⁴ Cn

⁵ Sr

⁶ Qc

⁷ Gl

⁸ Al


⁹ Sc

SAMPLE SUMMARY

WP1 GST L1772209-01 DW

Collected by: Ryan Deculus
 Collected date/time: 08/23/24 10:15
 Received date/time: 08/28/24 08:30

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2363860	1	09/18/24 11:50	09/18/24 13:06	DJS	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2361447	1	09/17/24 12:03	09/17/24 12:52	JPD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2353107	1	09/03/24 19:16	09/03/24 19:16	DWR	Mt. Juliet, TN



WP2 GST L1772209-02 DW

Collected by: Ryan Deculus
 Collected date/time: 08/23/24 10:20
 Received date/time: 08/28/24 08:30

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2363867	1	09/18/24 11:22	09/18/24 12:24	DJS	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2361447	1	09/17/24 12:03	09/17/24 12:55	JPD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2353107	1	09/03/24 19:39	09/03/24 19:39	DWR	Mt. Juliet, TN

157 OAK GROVE L1772209-03 DW

Collected by: Ryan Deculus
 Collected date/time: 08/23/24 10:35
 Received date/time: 08/28/24 08:30

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2363867	1	09/18/24 11:22	09/18/24 12:29	DJS	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2361447	1	09/17/24 12:03	09/17/24 12:58	JPD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2353107	1	09/03/24 20:01	09/03/24 20:01	DWR	Mt. Juliet, TN

144 RIDGETOP L1772209-04 DW

Collected by: Ryan Deculus
 Collected date/time: 08/23/24 10:28
 Received date/time: 08/28/24 08:30

Method	Batch	Dilution	Preparation date/time	Analysis date/time	Analyst	Location
Metals (ICP) by Method 200.7	WG2363867	1	09/18/24 11:22	09/18/24 12:30	DJS	Mt. Juliet, TN
Metals (ICPMS) by Method 200.8	WG2361447	1	09/17/24 12:03	09/17/24 13:01	JPD	Mt. Juliet, TN
Volatile Organic Compounds (GC/MS) by Method 524.2	WG2353107	1	09/03/24 20:24	09/03/24 20:24	DWR	Mt. Juliet, TN

CASE NARRATIVE

All sample aliquots were received at the correct temperature, in the proper containers, with the appropriate preservatives, and within method specified holding times, unless qualified or notated within the report. Where applicable, all MDL (LOD) and RDL (LOQ) values reported for environmental samples have been corrected for the dilution factor used in the analysis. All Method and Batch Quality Control are within established criteria except where addressed in this case narrative, a non-conformance form or properly qualified within the sample results. By my digital signature below, I affirm to the best of my knowledge, all problems/anomalies observed by the laboratory as having the potential to affect the quality of the data have been identified by the laboratory, and no information or data have been knowingly withheld that would affect the quality of the data.



Rodney Shinbaum
Project Manager

¹ Cp

² Tc

³ Ss

⁴ Cn

⁵ Sr

⁶ Qc

⁷ Gl

⁸ Al

⁹ Sc

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Barium	0.303		0.00500	2	1	09/18/2024 13:06	WG2363860	DJS
Calcium	20.3		1.00		1	09/18/2024 13:06	WG2363860	DJS
Chromium	ND		0.0100	0.10	1	09/18/2024 13:06	WG2363860	DJS
Copper	ND		0.0100	1	1	09/18/2024 13:06	WG2363860	DJS
Iron	0.523		0.0500	0.30	1	09/18/2024 13:06	WG2363860	DJS
Manganese	0.0201		0.0100	0.05	1	09/18/2024 13:06	WG2363860	DJS
Nickel	ND		0.0100	0.10	1	09/18/2024 13:06	WG2363860	DJS
Strontium	2.72		0.0100		1	09/18/2024 13:06	WG2363860	DJS
Zinc	ND		0.0500	5	1	09/18/2024 13:06	WG2363860	DJS

1 Cp

2 Tc

3 Ss

4 Cn

5 Sr

6 Qc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/17/2024 12:52	WG2361447	JPD
Antimony	ND		0.00500	0.0060	1	09/17/2024 12:52	WG2361447	JPD
Arsenic	ND		0.00100	0.01	1	09/17/2024 12:52	WG2361447	JPD
Beryllium	ND		0.00100	0.0040	1	09/17/2024 12:52	WG2361447	JPD
Lead	ND		0.00200	0.0150	1	09/17/2024 12:52	WG2361447	JPD
Selenium	ND		0.00200	0.05	1	09/17/2024 12:52	WG2361447	JPD
Thallium	ND		0.00100	0.0020	1	09/17/2024 12:52	WG2361447	JPD

7 Gl

8 Al

9 Sc

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/03/2024 19:16	WG2353107	DWR
Bromodichloromethane	ND		0.00100		1	09/03/2024 19:16	WG2353107	DWR
Chlorodibromomethane	ND		0.00100		1	09/03/2024 19:16	WG2353107	DWR
Bromoform	ND		0.00100		1	09/03/2024 19:16	WG2353107	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	09/03/2024 19:16	WG2353107	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Barium	0.277		0.00500	2	1	09/18/2024 12:24	WG2363867	DJS
Calcium	19.1		1.00		1	09/18/2024 12:24	WG2363867	DJS
Chromium	ND		0.0100	0.10	1	09/18/2024 12:24	WG2363867	DJS
Copper	ND		0.0100	1	1	09/18/2024 12:24	WG2363867	DJS
Iron	0.441		0.0500	0.30	1	09/18/2024 12:24	WG2363867	DJS
Manganese	0.0177		0.0100	0.05	1	09/18/2024 12:24	WG2363867	DJS
Nickel	ND		0.0100	0.10	1	09/18/2024 12:24	WG2363867	DJS
Strontium	2.54		0.0100		1	09/18/2024 12:24	WG2363867	DJS
Zinc	ND		0.0500	5	1	09/18/2024 12:24	WG2363867	DJS

1 Cp
2 Tc
3 Ss
4 Cn
5 Sr
6 Qc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/17/2024 12:55	WG2361447	JPD
Antimony	ND		0.00500	0.0060	1	09/17/2024 12:55	WG2361447	JPD
Arsenic	ND		0.00100	0.01	1	09/17/2024 12:55	WG2361447	JPD
Beryllium	ND		0.00100	0.0040	1	09/17/2024 12:55	WG2361447	JPD
Lead	ND		0.00200	0.0150	1	09/17/2024 12:55	WG2361447	JPD
Selenium	ND		0.00200	0.05	1	09/17/2024 12:55	WG2361447	JPD
Thallium	ND		0.00100	0.0020	1	09/17/2024 12:55	WG2361447	JPD

7 Gl
8 Al
9 Sc

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/03/2024 19:39	WG2353107	DWR
Bromodichloromethane	ND		0.00100		1	09/03/2024 19:39	WG2353107	DWR
Chlorodibromomethane	ND		0.00100		1	09/03/2024 19:39	WG2353107	DWR
Bromoform	ND		0.00100		1	09/03/2024 19:39	WG2353107	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	09/03/2024 19:39	WG2353107	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Barium	0.256		0.00500	2	1	09/18/2024 12:29	WG2363867	DJS
Calcium	17.8		1.00		1	09/18/2024 12:29	WG2363867	DJS
Chromium	ND		0.0100	0.10	1	09/18/2024 12:29	WG2363867	DJS
Copper	0.0312		0.0100	1	1	09/18/2024 12:29	WG2363867	DJS
Iron	0.441		0.0500	0.30	1	09/18/2024 12:29	WG2363867	DJS
Manganese	0.0103		0.0100	0.05	1	09/18/2024 12:29	WG2363867	DJS
Nickel	ND		0.0100	0.10	1	09/18/2024 12:29	WG2363867	DJS
Strontium	2.41		0.0100		1	09/18/2024 12:29	WG2363867	DJS
Zinc	ND		0.0500	5	1	09/18/2024 12:29	WG2363867	DJS

1 Cp
2 Tc
3 Ss
4 Cn
5 Sr
6 Qc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/17/2024 12:58	WG2361447	JPD
Antimony	ND		0.00500	0.0060	1	09/17/2024 12:58	WG2361447	JPD
Arsenic	ND		0.00100	0.01	1	09/17/2024 12:58	WG2361447	JPD
Beryllium	ND		0.00100	0.0040	1	09/17/2024 12:58	WG2361447	JPD
Lead	ND		0.00200	0.0150	1	09/17/2024 12:58	WG2361447	JPD
Selenium	ND		0.00200	0.05	1	09/17/2024 12:58	WG2361447	JPD
Thallium	ND		0.00100	0.0020	1	09/17/2024 12:58	WG2361447	JPD

7 Gl
8 Al
9 Sc

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/03/2024 20:01	WG2353107	DWR
Bromodichloromethane	ND		0.00100		1	09/03/2024 20:01	WG2353107	DWR
Chlorodibromomethane	ND		0.00100		1	09/03/2024 20:01	WG2353107	DWR
Bromoform	ND		0.00100		1	09/03/2024 20:01	WG2353107	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	09/03/2024 20:01	WG2353107	DWR

Metals (ICP) by Method 200.7

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Barium	0.269		0.00500	2	1	09/18/2024 12:30	WG2363867	DJS
Calcium	19.1		1.00		1	09/18/2024 12:30	WG2363867	DJS
Chromium	ND		0.0100	0.10	1	09/18/2024 12:30	WG2363867	DJS
Copper	0.0231		0.0100	1	1	09/18/2024 12:30	WG2363867	DJS
Iron	0.398		0.0500	0.30	1	09/18/2024 12:30	WG2363867	DJS
Manganese	ND		0.0100	0.05	1	09/18/2024 12:30	WG2363867	DJS
Nickel	ND		0.0100	0.10	1	09/18/2024 12:30	WG2363867	DJS
Strontium	2.55		0.0100		1	09/18/2024 12:30	WG2363867	DJS
Zinc	ND		0.0500	5	1	09/18/2024 12:30	WG2363867	DJS

1 Cp

2 Tc

3 Ss

4 Cn

5 Sr

6 Qc

Metals (ICPMS) by Method 200.8

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Aluminum	ND		0.100	0.20	1	09/17/2024 13:01	WG2361447	JPD
Antimony	ND		0.00500	0.0060	1	09/17/2024 13:01	WG2361447	JPD
Arsenic	ND		0.00100	0.01	1	09/17/2024 13:01	WG2361447	JPD
Beryllium	ND		0.00100	0.0040	1	09/17/2024 13:01	WG2361447	JPD
Lead	ND		0.00200	0.0150	1	09/17/2024 13:01	WG2361447	JPD
Selenium	ND		0.00200	0.05	1	09/17/2024 13:01	WG2361447	JPD
Thallium	ND		0.00100	0.0020	1	09/17/2024 13:01	WG2361447	JPD

7 Gl

8 Al

9 Sc

Volatile Organic Compounds (GC/MS) by Method 524.2

Analyte	Result	Qualifier	Det. Limit	Reference Limit	Dilution	Analysis	Batch	Analyst
	mg/l		mg/l	mg/l		date / time		
Chloroform	ND		0.00100		1	09/03/2024 20:24	WG2353107	DWR
Bromodichloromethane	ND		0.00100		1	09/03/2024 20:24	WG2353107	DWR
Chlorodibromomethane	ND		0.00100		1	09/03/2024 20:24	WG2353107	DWR
Bromoform	ND		0.00100		1	09/03/2024 20:24	WG2353107	DWR
Total Trihalomethanes	ND		0.00100	0.08	1	09/03/2024 20:24	WG2353107	DWR

Method Blank (MB)

(MB) R4121207-1 09/18/24 12:40

Analyte	MB Result	MB Qualifier	MB MDL	MB RDL
	mg/l		mg/l	mg/l
Barium	U		0.000795	0.00500
Calcium	U		0.0473	1.00
Chromium	U		0.00163	0.0100
Copper	U		0.00226	0.0100
Iron	U		0.0205	0.0500
Manganese	U		0.000855	0.0100
Nickel	U		0.00182	0.0100
Strontium	U		0.000683	0.0100
Zinc	U		0.00578	0.0500

¹Cp

²Tc

³Ss

⁴Cn

⁵Sr

⁶Qc

Laboratory Control Sample (LCS)

(LCS) R4121207-2 09/18/24 12:42

Analyte	Spike Amount	LCS Result	LCS Rec.	Rec. Limits	LCS Qualifier
	mg/l	mg/l	%	%	
Barium	1.00	1.06	106	85.0-115	
Calcium	10.0	10.4	104	85.0-115	
Chromium	1.00	1.04	104	85.0-115	
Copper	1.00	1.05	105	85.0-115	
Iron	10.0	10.0	100	85.0-115	
Manganese	1.00	1.05	105	85.0-115	
Nickel	1.00	0.967	96.7	85.0-115	
Strontium	1.00	1.04	104	85.0-115	
Zinc	1.00	1.01	101	85.0-115	

⁷Gl

⁸Al

⁹Sc

L1771824-01 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1771824-01 09/18/24 12:44 • (MS) R4121207-3 09/18/24 12:46 • (MSD) R4121207-4 09/18/24 12:47

Analyte	Spike Amount	Original Result	MS Result	MSD Result	MS Rec.	MSD Rec.	Dilution	Rec. Limits	MS Qualifier	MSD Qualifier	RPD	RPD Limits
	mg/l	mg/l	mg/l	mg/l	%	%		%			%	%
Barium	1.00	0.0236	1.05	1.05	103	102	1	75.0-125			0.437	20
Calcium	10.0	11.5	21.4	21.2	99.3	97.8	1	75.0-125			0.733	20
Chromium	1.00	ND	1.02	1.02	102	102	1	75.0-125			0.538	20
Copper	1.00	ND	1.02	1.02	102	102	1	75.0-125			0.208	20
Iron	10.0	ND	9.90	9.90	99.0	99.0	1	75.0-125			0.0200	20
Manganese	1.00	ND	1.02	1.03	102	103	1	75.0-125			0.0346	20
Nickel	1.00	ND	0.946	0.953	94.6	95.3	1	75.0-125			0.657	20
Strontium	1.00	0.0423	1.06	1.05	102	101	1	75.0-125			0.574	20
Zinc	1.00	ND	0.991	0.985	99.1	98.5	1	75.0-125			0.591	20

Method Blank (MB)

(MB) R4121206-1 09/18/24 12:20

Analyte	MB Result	MB Qualifier	MB MDL	MB RDL
	mg/l		mg/l	mg/l
Barium	U		0.000795	0.00500
Calcium	U		0.0473	1.00
Chromium	U		0.00163	0.0100
Copper	U		0.00226	0.0100
Iron	U		0.0205	0.0500
Manganese	U		0.000855	0.0100
Nickel	U		0.00182	0.0100
Strontium	U		0.000683	0.0100
Zinc	U		0.00578	0.0500

1 Cp

2 Tc

3 Ss

4 Cn

5 Sr

6 Qc

Laboratory Control Sample (LCS)

(LCS) R4121206-2 09/18/24 12:22

Analyte	Spike Amount	LCS Result	LCS Rec.	Rec. Limits	LCS Qualifier
	mg/l	mg/l	%	%	
Barium	1.00	1.06	106	85.0-115	
Calcium	10.0	10.7	107	85.0-115	
Chromium	1.00	1.07	107	85.0-115	
Copper	1.00	1.07	107	85.0-115	
Iron	10.0	10.4	104	85.0-115	
Manganese	1.00	1.06	106	85.0-115	
Nickel	1.00	0.976	97.6	85.0-115	
Strontium	1.00	1.06	106	85.0-115	
Zinc	1.00	1.00	100	85.0-115	

7 Gl

8 Al

9 Sc

L1772209-02 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1772209-02 09/18/24 12:24 • (MS) R4121206-3 09/18/24 12:25 • (MSD) R4121206-4 09/18/24 12:27

Analyte	Spike Amount	Original Result	MS Result	MSD Result	MS Rec.	MSD Rec.	Dilution	Rec. Limits	MS Qualifier	MSD Qualifier	RPD	RPD Limits
	mg/l	mg/l	mg/l	mg/l	%	%		%			%	%
Barium	1.00	0.277	1.27	1.27	99.6	98.8	1	75.0-125			0.652	20
Calcium	10.0	19.1	28.8	29.1	97.4	100	1	75.0-125			0.994	20
Chromium	1.00	ND	1.02	1.00	102	100	1	75.0-125			1.78	20
Copper	1.00	ND	0.986	0.983	98.6	98.3	1	75.0-125			0.218	20
Iron	10.0	0.441	10.3	10.3	98.4	98.6	1	75.0-125			0.185	20
Manganese	1.00	0.0177	1.03	1.02	101	99.9	1	75.0-125			1.08	20
Nickel	1.00	ND	0.982	0.988	98.0	98.6	1	75.0-125			0.694	20
Strontium	1.00	2.54	3.50	3.54	96.0	99.5	1	75.0-125			0.972	20
Zinc	1.00	ND	1.02	1.01	99.6	98.7	1	75.0-125			0.883	20

Method Blank (MB)

(MB) R4120727-1 09/17/24 13:25

Analyte	MB Result mg/l	MB Qualifier	MB MDL mg/l	MB RDL mg/l
Aluminum	U		0.0470	0.100
Antimony	U		0.00172	0.00500
Arsenic	U		0.000195	0.00100
Beryllium	U		0.000201	0.00100
Lead	U		0.000513	0.00200
Selenium	U		0.000437	0.00200
Thallium	U		0.000176	0.00100

¹Cp

²Tc

³Ss

⁴Cn

⁵Sr

Laboratory Control Sample (LCS)

(LCS) R4120727-2 09/17/24 13:28

Analyte	Spike Amount mg/l	LCS Result mg/l	LCS Rec. %	Rec. Limits %	LCS Qualifier
Aluminum	1.00	0.998	99.8	85.0-115	
Antimony	0.0500	0.0518	104	85.0-115	
Arsenic	0.0500	0.0500	100	85.0-115	
Beryllium	0.0500	0.0484	96.7	85.0-115	
Lead	0.0500	0.0501	100	85.0-115	
Selenium	0.0500	0.0476	95.1	85.0-115	
Thallium	0.0500	0.0490	97.9	85.0-115	

⁶Qc

⁷Gl

⁸Al

⁹Sc

L1771956-15 Original Sample (OS) • Matrix Spike (MS) • Matrix Spike Duplicate (MSD)

(OS) L1771956-15 09/17/24 13:31 • (MS) R4120727-3 09/17/24 13:34 • (MSD) R4120727-4 09/17/24 13:37

Analyte	Spike Amount mg/l	Original Result mg/l	MS Result mg/l	MSD Result mg/l	MS Rec. %	MSD Rec. %	Dilution	Rec. Limits %	MS Qualifier	MSD Qualifier	RPD %	RPD Limits %
Aluminum	1.00	ND	1.06	1.05	106	105	1	70.0-130			0.173	20
Antimony	0.0500	ND	0.0554	0.0553	111	111	1	70.0-130			0.127	20
Arsenic	0.0500	ND	0.0528	0.0522	105	104	1	70.0-130			1.16	20
Beryllium	0.0500	ND	0.0491	0.0495	98.2	99.0	1	70.0-130			0.802	20
Lead	0.0500	ND	0.0517	0.0518	102	103	1	70.0-130			0.233	20
Selenium	0.0500	ND	0.0495	0.0505	98.9	101	1	70.0-130			2.01	20
Thallium	0.0500	ND	0.0506	0.0500	101	100	1	70.0-130			1.20	20

Method Blank (MB)

(MB) R4115279-2 09/03/24 10:33

Analyte	MB Result	MB Qualifier	MB MDL	MB RDL
	mg/l		mg/l	mg/l
Chloroform	U		0.0000800	0.00100
Bromodichloromethane	U		0.0000810	0.00100
Chlorodibromomethane	U		0.0000930	0.00100
Bromoform	U		0.0000800	0.00100
Total Trihalomethanes	U		0.000334	0.00100

Laboratory Control Sample (LCS)

(LCS) R4115279-1 09/03/24 09:47

Analyte	Spike Amount	LCS Result	LCS Rec.	Rec. Limits	LCS Qualifier
	mg/l	mg/l	%	%	
Chloroform	0.00500	0.00508	102	70.0-130	
Bromodichloromethane	0.00500	0.00502	100	70.0-130	
Chlorodibromomethane	0.00500	0.00482	96.4	70.0-130	
Bromoform	0.00500	0.00461	92.2	70.0-130	
Total Trihalomethanes	0.0200	0.0195	97.5	70.0-130	

¹Cp

²Tc

³Ss

⁴Cn

⁵Sr

⁶Qc

⁷Gl

⁸Al

⁹Sc

GLOSSARY OF TERMS

Guide to Reading and Understanding Your Laboratory Report

The information below is designed to better explain the various terms used in your report of analytical results from the Laboratory. This is not intended as a comprehensive explanation, and if you have additional questions please contact your project representative.


Results Disclaimer - Information that may be provided by the customer, and contained within this report, include Permit Limits, Project Name, Sample ID, Sample Matrix, Sample Preservation, Field Blanks, Field Spikes, Field Duplicates, On-Site Data, Sampling Collection Dates/Times, and Sampling Location. Results relate to the accuracy of this information provided, and as the samples are received.

Abbreviations and Definitions

MDL	Method Detection Limit.
ND	Not detected at the Reporting Limit (or MDL where applicable).
RDL	Reported Detection Limit.
Rec.	Recovery.
RPD	Relative Percent Difference.
SDG	Sample Delivery Group.
U	Not detected at the Reporting Limit (or MDL where applicable).
Analyte	The name of the particular compound or analysis performed. Some Analyses and Methods will have multiple analytes reported.
Dilution	If the sample matrix contains an interfering material, the sample preparation volume or weight values differ from the standard, or if concentrations of analytes in the sample are higher than the highest limit of concentration that the laboratory can accurately report, the sample may be diluted for analysis. If a value different than 1 is used in this field, the result reported has already been corrected for this factor.
Limits	These are the target % recovery ranges or % difference value that the laboratory has historically determined as normal for the method and analyte being reported. Successful QC Sample analysis will target all analytes recovered or duplicated within these ranges.
Original Sample	The non-spiked sample in the prep batch used to determine the Relative Percent Difference (RPD) from a quality control sample. The Original Sample may not be included within the reported SDG.
Qualifier	This column provides a letter and/or number designation that corresponds to additional information concerning the result reported. If a Qualifier is present, a definition per Qualifier is provided within the Glossary and Definitions page and potentially a discussion of possible implications of the Qualifier in the Case Narrative if applicable.
Result	The actual analytical final result (corrected for any sample specific characteristics) reported for your sample. If there was no measurable result returned for a specific analyte, the result in this column may state "ND" (Not Detected) or "BDL" (Below Detectable Levels). The information in the results column should always be accompanied by either an MDL (Method Detection Limit) or RDL (Reporting Detection Limit) that defines the lowest value that the laboratory could detect or report for this analyte.
Uncertainty (Radiochemistry)	Confidence level of 2 sigma.
Case Narrative (Cn)	A brief discussion about the included sample results, including a discussion of any non-conformances to protocol observed either at sample receipt by the laboratory from the field or during the analytical process. If present, there will be a section in the Case Narrative to discuss the meaning of any data qualifiers used in the report.
Quality Control Summary (Qc)	This section of the report includes the results of the laboratory quality control analyses required by procedure or analytical methods to assist in evaluating the validity of the results reported for your samples. These analyses are not being performed on your samples typically, but on laboratory generated material.
Sample Chain of Custody (Sc)	This is the document created in the field when your samples were initially collected. This is used to verify the time and date of collection, the person collecting the samples, and the analyses that the laboratory is requested to perform. This chain of custody also documents all persons (excluding commercial shippers) that have had control or possession of the samples from the time of collection until delivery to the laboratory for analysis.
Sample Results (Sr)	This section of your report will provide the results of all testing performed on your samples. These results are provided by sample ID and are separated by the analyses performed on each sample. The header line of each analysis section for each sample will provide the name and method number for the analysis reported.
Sample Summary (Ss)	This section of the Analytical Report defines the specific analyses performed for each sample ID, including the dates and times of preparation and/or analysis.

Qualifier Description

The remainder of this page intentionally left blank, there are no qualifiers applied to this SDG.



ACCREDITATIONS & LOCATIONS


Pace Analytical National 12065 Lebanon Rd Mount Juliet, TN 37122






Alabama	40660	Nebraska	NE-OS-15-05
Alaska	17-026	Nevada	TN000032021-1
Arizona	AZ0612	New Hampshire	2975
Arkansas	88-0469	New Jersey–NELAP	TN002
California	2932	New Mexico ¹	TN00003
Colorado	TN00003	New York	11742
Connecticut	PH-0197	North Carolina	Env375
Florida	E87487	North Carolina ¹	DW21704
Georgia	NELAP	North Carolina ³	41
Georgia ¹	923	North Dakota	R-140
Idaho	TN00003	Ohio–VAP	CL0069
Illinois	200008	Oklahoma	9915
Indiana	C-TN-01	Oregon	TN200002
Iowa	364	Pennsylvania	68-02979
Kansas	E-10277	Rhode Island	LA000356
Kentucky ^{1,6}	KY90010	South Carolina	84004002
Kentucky ²	16	South Dakota	n/a
Louisiana	AI30792	Tennessee ^{1,4}	2006
Louisiana	LA018	Texas	T104704245-20-18
Maine	TN00003	Texas ⁵	LAB0152
Maryland	324	Utah	TN000032021-11
Massachusetts	M-TN003	Vermont	VT2006
Michigan	9958	Virginia	110033
Minnesota	047-999-395	Washington	C847
Mississippi	TN00003	West Virginia	233
Missouri	340	Wisconsin	998093910
Montana	CERT0086	Wyoming	A2LA
A2LA – ISO 17025	1461.01	AIHA-LAP,LLC EMLAP	100789
A2LA – ISO 17025 ⁵	1461.02	DOD	1461.01
Canada	1461.01	USDA	P330-15-00234
EPA–Crypto	TN00003		

¹ Drinking Water ² Underground Storage Tanks ³ Aquatic Toxicity ⁴ Chemical/Microbiological ⁵ Mold ⁶ Wastewater n/a Accreditation not applicable

* Not all certifications held by the laboratory are applicable to the results reported in the attached report.

* Accreditation is only applicable to the test methods specified on each scope of accreditation held by Pace Analytical.



Water Utility Services, Inc 21615 Rhodes Rd. Spring, TX 77388		Billing Information: Water Utility Services P.O. Box 2628 Spring, TX 77383		Pres Chk	Analysis / Container / Preservative										Chain of Custody Page ___ of ___																																																																																																												
Report to: Steve Grychka		Email To: steve@waterutilityservice.com													 12065 Lebanon Rd Mount Juliet, TN 37122 Phone: 615-758-5858 Phone: 800-767-5859 Fax: 615-758-5859																																																																																																												
Project Description: New Fairview MUD 1		City/State Collected: TX													L# <u>61772209</u> E090																																																																																																												
Phone: 281-290-0704 Fax:		Client Project #		Lab Project #													Acctnum: WATERSTX01 Template: Prelogin: TSR: Rodney Shinbaum PB:																																																																																																										
Collected by (print): Ryan Deculus		Site/Facility ID #		P.O. #													Shipped Via:																																																																																																										
Collected by (signature): Immediately Packed on Ice N ___ Y <input checked="" type="checkbox"/>		Rush? (Lab MUST Be Notified) <input type="checkbox"/> Same Day <input type="checkbox"/> Five Day <input type="checkbox"/> Next Day <input type="checkbox"/> 5 Day (Rad Only) <input type="checkbox"/> Two Day <input type="checkbox"/> 10 Day (Rad Only) <input type="checkbox"/> Three Day		Quote #		Date Results Needed		No. of Cntrs											Remarks Sample # (lab only)																																																																																																								
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Sample ID</th> <th>Comp/Grab</th> <th>Matrix *</th> <th>Depth</th> <th>Date</th> <th>Time</th> <th>No. of Cntrs</th> <th>TTAMS</th> <th>As</th> <th>Ca</th> <th>Cr</th> <th>Cu</th> <th>Ni</th> <th>Pb</th> <th>Zn</th> <th>Fe</th> <th>Mn</th> <th>Sb</th> <th>Ba</th> <th>Be</th> <th>Se</th> <th>Tl</th> <th>Sr</th> <th>Al</th> </tr> </thead> <tbody> <tr> <td>WP1 GST</td> <td>G</td> <td>DW</td> <td></td> <td>8-23-24</td> <td>1015</td> <td>3</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>WP2 GST</td> <td>G</td> <td>DW</td> <td></td> <td>↓</td> <td>1020</td> <td>3</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>157 Oak Grove</td> <td>G</td> <td>DW</td> <td></td> <td>↓</td> <td>1035</td> <td>3</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>144 Ridgertop</td> <td>G</td> <td>DW</td> <td></td> <td>↓</td> <td>1028</td> <td>3</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> </tbody> </table>		Sample ID	Comp/Grab	Matrix *	Depth	Date	Time	No. of Cntrs	TTAMS	As	Ca	Cr	Cu	Ni	Pb	Zn	Fe	Mn	Sb	Ba	Be	Se	Tl	Sr	Al	WP1 GST	G	DW		8-23-24	1015	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	WP2 GST	G	DW		↓	1020	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	157 Oak Grove	G	DW		↓	1035	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	144 Ridgertop	G	DW		↓	1028	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
Sample ID	Comp/Grab	Matrix *	Depth	Date	Time	No. of Cntrs	TTAMS	As	Ca	Cr	Cu	Ni	Pb	Zn	Fe	Mn	Sb	Ba	Be	Se	Tl	Sr	Al																																																																																																				
WP1 GST	G	DW		8-23-24	1015	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																																																																																																				
WP2 GST	G	DW		↓	1020	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																																																																																																				
157 Oak Grove	G	DW		↓	1035	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																																																																																																				
144 Ridgertop	G	DW		↓	1028	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																																																																																																				
* Matrix: SS - Soil AIR - Air F - Filter GW - Groundwater B - Bioassay WW - WasteWater DW - Drinking Water OT - Other _____		Remarks:		Samples returned via: <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Courier _____		Tracking #												pH _____ Temp _____ Flow _____ Other _____																																																																																																									
Relinquished by: (Signature) 		Date: 8/27/24		Time: 14:45		Received by: (Signature) 		Trip Blank Received: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		HCL / MeOH TBR												Sample Receipt Checklist COC Seal Present/Intact: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N COC Signed/Accurate: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Bottles arrive intact: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Correct bottles used: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Sufficient volume sent: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N If Applicable VOA Zero Headspace: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Preservation Correct/Checked: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N																																																																																																					
Relinquished by: (Signature) 		Date: 8/27/24		Time: 13:00		Received by: (Signature)		Temp: °C Bottles Received: 5.6±0.3 = 5.9 12												If preservation required by Login: Date/Time																																																																																																							
Relinquished by: (Signature)		Date:		Time:		Received for lab by: (Signature) 		Date: 8-28-24 Time: 830												Hold: Condition: NCF / <input checked="" type="checkbox"/> OK																																																																																																							